

OCT 27 2021

Docket No.: 52-025

ND-21-0968
10 CFR 52.99(c)(1)U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555-0001

Southern Nuclear Operating Company
Vogtle Electric Generating Plant Unit 3
ITAAC Closure Notification on Completion of ITAAC E.3.9.06.00.04 [Index Number 862]


Ladies and Gentlemen:

In accordance with 10 CFR 52.99(c)(1), the purpose of this letter is to notify the Nuclear Regulatory Commission (NRC) of the completion of Vogtle Electric Generating Plant (VEGP) Unit 3 Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC) Item E.3.9.06.00.04 [Index Number 862]. This ITAAC confirms that the appropriate meteorological parameter information is displayed in the VEGP Unit 3 Main Control Room and Technical Support Center. The closure process for this ITAAC is based on the guidance described in Nuclear Energy Institute (NEI) 08-01, "Industry Guideline for the ITAAC Closure Process Under 10 CFR Part 52," which was endorsed by the NRC in Regulatory Guide 1.215.

This letter contains no new NRC regulatory commitments. Southern Nuclear Operating Company (SNC) requests NRC staff confirmation of this determination and publication of the required notice in the Federal Register per 10 CFR 52.99.

If there are any questions, please contact Kelli Roberts at 706-848-6991.

Respectfully submitted,

Michael J. Yox
Regulatory Affairs Director Vogtle 3 & 4

Enclosure: Vogtle Electric Generating Plant (VEGP) Unit 3
Completion of ITAAC E.3.9.06.00.04 [Index Number 862]

MJY/RLB/sfr

To:

Southern Nuclear Operating Company/ Georgia Power Company

Mr. Peter P. Sena III

Mr. D. L. McKinney

Mr. H. Nieh

Mr. G. Chick

Mr. S. Stimac

Mr. P. Martino

Mr. M. J. Yox

Mr. A. S. Parton

Ms. K. A. Roberts

Ms. J.M. Coleman

Mr. C. T. Defnall

Mr. C. E. Morrow

Mr. K. J. Drudy

Mr. J. M. Fisher

Mr. R. L. Beilke

Mr. S. Leighty

Ms. A. C. Chamberlain

Mr. J. C. Haswell

Document Services RTYPE: VND.LI.L06

File AR.01.02.06

cc:

Nuclear Regulatory Commission

Ms. M. Bailey

Mr. M. King

Mr. G. Bowman

Ms. A. Veil

Mr. C. P. Patel

Mr. G. J. Khouri

Mr. C. J. Even

Mr. B. J. Kemker

Ms. N. C. Coover

Mr. C. Welch

Mr. J. Gaslevic

Mr. O. Lopez-Santiago

Mr. G. Armstrong

Mr. M. Webb

Mr. T. Fredette

Mr. C. Santos

Mr. B. Davis

Mr. J. Vasquez

Mr. J. Eargle

Mr. E. Davidson

Mr. T. Fanelli

Ms. K. McCurry

Mr. J. Parent

Mr. B. Griman

Mr. V. Hall

Oglethorpe Power Corporation

Mr. R. B. Brinkman
Mr. E. Rasmussen

Municipal Electric Authority of Georgia

Mr. J. E. Fuller
Mr. S. M. Jackson

Dalton Utilities

Mr. T. Bundros

Westinghouse Electric Company, LLC

Dr. L. Oriani (w/o enclosures)
Mr. D. C. Durham (w/o enclosures)
Mr. M. M. Corletti
Mr. Z. S. Harper
Mr. J. L. Coward

Other

Mr. S. W. Kline, *Bechtel Power Corporation*
Ms. L. Matis, *Tetra Tech NUS, Inc.*
Dr. W. R. Jacobs, Jr., Ph.D., *GDS Associates, Inc.*
Mr. S. Roetger, *Georgia Public Service Commission*
Mr. R. L. Trokey, *Georgia Public Service Commission*
Mr. K. C. Greene, *Troutman Sanders*
Mr. S. Blanton, *Balch Bingham*

**Southern Nuclear Operating Company
ND-21-0968
Enclosure**

**Vogtle Electric Generating Plant (VEGP) Unit 3
Completion of ITAAC E.3.9.06.00.04 [Index Number 862]**

ITAAC Statement

Program Commitment

6.4 The means exists to acquire and evaluate meteorological information. [I.5]

Inspections/Tests/Analyses

6.4 A test will be performed to verify the ability to access meteorological information in the TSC and control room.

Acceptance Criteria

6.4 The following parameters are displayed in the TSC and control room:

- Wind speed (at 10 and 60 meters)
- Wind direction (at 10 and 60 meters)
- Standard deviation of horizontal wind direction (at 10 meters)
- Vertical temperature difference (between 10 and 60 meters)
- Ambient temperature (at 10 meters)
- Dew-point temperature (at 10 meters)
- Precipitation (at the tower base)

ITAAC Determination Basis

A test was performed to demonstrate that the means exists to acquire and evaluate meteorological information by verifying the ability to access meteorological information in the Technical Support Center (TSC) and the control room.

The test was performed using ITAAC Technical Report SV3-MES-ITR-800862, Meteorological Information Verification, (Reference 1) and verified the following parameters are displayed in the TSC and control room:

- Wind speed (at 10 and 60 meters)
- Wind direction (at 10 and 60 meters)
- Standard deviation of horizontal wind direction (at 10 meters)
- Vertical temperature difference (between 10 and 60 meters)
- Ambient temperature (at 10 meters)
- Dew-point temperature (at 10 meters)
- Precipitation (at the tower base)

The results of the test are documented in Reference 1 and confirm that the following parameters are displayed in the TSC and control room:

- Wind speed (at 10 and 60 meters)
- Wind direction (at 10 and 60 meters)
- Standard deviation of horizontal wind direction (at 10 meters)
- Vertical temperature difference (between 10 and 60 meters)
- Ambient temperature (at 10 meters)
- Dew-point temperature (at 10 meters)
- Precipitation (at the tower base)

Reference 1 is available for NRC inspection as part of the Unit 3 ITAAC E.3.9.06.00.04 Completion Package (Reference 2).

ITAAC Finding Review

In accordance with plant procedures for ITAAC completion, Southern Nuclear Operating Company (SNC) performed a review of all findings pertaining to the subject ITAAC and associated corrective actions. This review found there were no relevant ITAAC findings associated with this ITAAC. The ITAAC completion review is documented in the ITAAC Completion Package for ITAAC E.3.9.06.00.04 (Reference 2) and is available for NRC review.

ITAAC Completion Statement

Based on the above information, SNC hereby notifies the NRC that ITAAC E.3.9.06.00.04 was performed for VEGP Unit 3 and that the prescribed acceptance criteria were met.

Systems, structures, and components verified as part of this ITAAC are being maintained in their as-designed, ITAAC compliant condition in accordance with approved plant programs and procedures.

References (available for NRC inspection)

1. SV3-MES-ITR-800862, Meteorological Information Verification, Rev 0
2. E.3.9.06.00.04-U3-CP-Rev0, ITAAC Completion Package